

---

P2001647 –Brighton 3Ts

---

Standard Rooms Batch 2 Derogations Schedule

Produced by: Kirsty Pearson

Outline description: Descriptions of derogations with BDP comments

Doc No: BDP-AR-SW-SH-S002  
Issue: For Information  
Rev: F02  
Published Date: 28 February 2011

**BDP.**

Batch	Room No.	Room Name	Description of derogation	Reference document	BDP Comments
Batch 2	S151	Rest room with beverage: snack preparation bay: 38 staff with emergency call lamp	<ol style="list-style-type: none"> <li>1. 750mm is recommended for the table size per user. 600mm is shown.</li> <li>2. The space zone for a place setting on a table is recommended to be 400mm x 600mm. 300 x 600 is shown. Four chairs sitting at the end of the tables do not have any place setting.</li> <li>3. A 100mm gap is recommended between the easy chairs and the wall.</li> <li>4. 600mm is recommended behind the dining chairs to allow ambulant passing. We show 470mm between the dining chair and easy chair.</li> </ol>	<ol style="list-style-type: none"> <li>1. HBN00-03 Clinical and clinical support spaces; pg 79, fig A16</li> <li>2. HBN00-03 Clinical and clinical support spaces; pg 79, fig A16</li> <li>3. HBN00-03 Clinical and clinical support spaces; pg 77 fig A14 and pg 50 fig 39.</li> <li>4. HBN00-03 Clinical and clinical support spaces; pg 79 fig A16 and pg 50 fig 39.</li> </ol>	<p>Derogation no. 3 could be eliminated if we create the 100mm gap between the chair and wall.</p> <p>The four chairs that do not have a place setting as described in derogation no. 2 could be eliminated if 2no. tables were added.</p>
Batch 2	S148	Rest room with beverage : snack preparation : 36 staff with emergency call lamp	<ol style="list-style-type: none"> <li>1. 750mm is recommended for the table size per user. 600mm is shown.</li> <li>2. The space zone for a place setting on a table should be 400mm x 600mm. 300 x 600 is shown. Four chairs sitting at the end of the tables do not have any place setting.</li> <li>3. A 100mm gap is recommended between the easy chairs and the wall.</li> <li>4. 600mm is recommended behind the dining chairs to allow ambulant passing. 480mm between the dining chair and easy chair is shown.</li> </ol>	<ol style="list-style-type: none"> <li>1. HBN00-03 Clinical and clinical support spaces; pg 79, fig A16</li> <li>2. HBN00-03 Clinical and clinical support spaces; pg 79, fig A16</li> <li>3. HBN00-03 Clinical and clinical support spaces; pg 77 fig A14 and pg 50 fig 39.</li> <li>4. HBN00-03 Clinical and clinical support spaces; pg 79 fig A16 and pg 50 fig 39.</li> </ol>	<p>Derogation no. 3 could be eliminated if we create the 100mm gap between the chair and wall.</p> <p>The four chairs that do not have a place setting as described in derogation no. 2 could be eliminated if 2no. tables were added.</p>
Batch 2	S099A and S099B	Rest room with beverage: snack preparation bay : 25 staff with emergency call lamp	<ol style="list-style-type: none"> <li>1. 750mm is recommended for the table size per user. 600mm is shown.</li> <li>2. The space zone for a place setting on a table should be 400mm x 600mm. 300 x 600 is shown. Two chairs sitting at the end of the tables do not have any place setting.</li> <li>3. 1350mm is recommended for space between the easy chairs for leg space and ambulant passing. 940mm and 1130mm is shown in S099A and 890mm and 1240mm is shown in S099B.</li> <li>4. A 100mm gap is recommended between the easy chairs and the wall.</li> </ol>	<ol style="list-style-type: none"> <li>1. HBN00-03 Clinical and clinical support spaces; pg 79, fig A16</li> <li>2. HBN00-03 Clinical and clinical support spaces; pg 79, fig A16</li> <li>3. HBN00-03 Clinical and clinical support spaces; pg 50, fig 39 and pg 77 fig A14.</li> <li>4. HBN00-03 Clinical and clinical support spaces; pg 77 fig A14 and pg 50 fig 39.</li> </ol>	

DEROGATION SCHEDULE  
1:50 STANDARD ROOMS

**BATCH 2**

**F01 - 31/01/11**

**F02 - 28/02/11**

Batch	Room No.	Room Name	Description of derogation	Reference document	BDP Comments
Batch 2	S154	Rest room with beverage : snack preparation bay: 20 staff with emergency call	<ol style="list-style-type: none"> <li>1. 750mm is recommended for the table size per user. 600mm is shown.</li> <li>2. The space zone for a place setting on a table should be 400mm x 600mm. 300 x 600 is shown. Two chairs sitting at the end of the tables do not have any place setting.</li> <li>3. 1350mm is recommended for space between the easy chairs for leg space and ambulant passing. 970mm and 1160mm is shown.</li> <li>4. A 100mm gap is recommended between the easy chairs and the wall.</li> </ol>	<ol style="list-style-type: none"> <li>1. HBN00-03 Clinical and clinical support spaces;pg 79, fig A16</li> <li>2. HBN00-03 Clinical and clinical support spaces; pg 79, fig A16.</li> <li>3. HBN00-03 Clinical and clinical support spaces; pg 50, fig 39 and pg 77 fig A14.</li> <li>4. HBN00-03 Clinical and clinical support spaces; pg 77 fig A14 and pg 50 fig 39.</li> </ol>	
Batch 2	S152	Rest room 16 staff	<ol style="list-style-type: none"> <li>1. 750mm is recommended for the table size per user. 600mm is shown.</li> <li>2. The space zone for a place setting on a table should be 400mm x 600mm. 300 x 600 is shown.</li> <li>3. 900mm is recommended for space in front of the easy chairs for leg space and ambulant passing. This space is obstructed by the chairs (CHA018). 800mm and 470mm is shown.</li> <li>4. A 100mm gap is recommended between the easy chairs and the wall.</li> <li>5. The space zone for working at the sink (1000mm x 1000mm) and worktop (1000mm depth) overlaps the dining tables by 90mm.</li> </ol>	<ol style="list-style-type: none"> <li>1. HBN00-03 Clinical and clinical support spaces;pg 79, fig A16</li> <li>2. HBN00-03 Clinical and clinical support spaces; pg 79, fig A16</li> <li>3. HBN00-03 Clinical and clinical support spaces; pg 50, fig 39 and pg 77 fig A14.</li> <li>4. HBN00-03 Clinical and clinical support spaces; pg 77 fig A14 and pg 50 fig 39.</li> <li>5. HBN00-03 Clinical and clinical support spaces; pg 82, figA19, pg 66 fig A3, pg 50 fig 39.</li> </ol>	
Batch 2	S147	Rest room with beverage: snack preparation bay: 16 staff with emergency call lamp	<ol style="list-style-type: none"> <li>1. 750mm is recommended for the table size per user. 600mm is shown.</li> <li>2. The space zone for a place setting on a table should be 400mm x 600mm. 300 x 600 is shown. Two chairs sitting at the end of the tables do not have any place setting.</li> <li>3. 900mm is recommended for space in front of the easy chairs for leg space and ambulant passing. This space is obstructed by chairs (CHA018). 740mm and 475mm is shown.</li> <li>4. A 100mm gap is recommended between the easy chairs and the wall.</li> <li>5. 800mm is recommended for space for withdrawal of chair from the table. 740mm is shown between the chairs and the easy chairs.</li> <li>6. The space zone for working at the sink (1000mm x 1000mm) and worktop (1000mm depth) overlaps the dining tables by 30mm.</li> </ol>	<ol style="list-style-type: none"> <li>1. HBN00-03 Clinical and clinical support spaces;pg 79, fig A16</li> <li>2. HBN00-03 Clinical and clinical support spaces; pg 79, fig A16</li> <li>3. HBN00-03 Clinical and clinical support spaces; pg 50, fig 39 and pg 77 fig A14.</li> <li>4. HBN00-03 Clinical and clinical support spaces; pg 77 fig A14 and pg 50 fig 39.</li> <li>5. HBN00-03 Clinical and clinical support spaces; pg 78 fig A16 and pg 50 fig 39.</li> <li>6. HBN00-03 Clinical and clinical support spaces; pg 82, figA19, pg 66 fig A3, pg 50 fig 39.</li> </ol>	For derogation no. 5, we have based the 800mm for the withdrawal of chair on fig A15 illustrating working at a desk/table. This is because there is no dimension on fig A16 which illustrate the dining table/chair arrangement.

DEROGATION SCHEDULE

1:50 STANDARD ROOMS

**BATCH 2**

**F01 - 31/01/11**

**F02 - 28/02/11**

Batch	Room No.	Room Name	Description of derogation	Reference document	BDP Comments
Batch 2	S150	Rest room 16 staff & lockers	<ol style="list-style-type: none"> <li>750mm is recommended for the table size per user. 600mm is shown.</li> <li>The space zone for a place setting on a table should be 400mm x 600mm. 300 x 600 is shown.</li> <li>900mm is recommended for space in front of the easy chairs for leg space and ambulant passing. This space is obstructed by TAB9000. 507mm is shown.</li> <li>A 100mm gap is recommended between the easy chairs and the wall.</li> </ol>	<ol style="list-style-type: none"> <li>HBN00-03 Clinical and clinical support spaces; pg 79, fig A16</li> <li>HBN00-03 Clinical and clinical support spaces; pg 79, fig A16</li> <li>HBN00-03 Clinical and clinical support spaces; pg 50, fig 39 and pg 77 fig A14.</li> <li>HBN00-03 Clinical and clinical support spaces; pg 78 fig A16 and pg 50 fig 39.</li> </ol>	
Batch 2	S098	Rest room 12 staff	<ol style="list-style-type: none"> <li>750mm is recommended for the table size per user. 600mm is shown.</li> <li>The space zone for a place setting on a table should be 400mm x 600mm. 300 x 600 is shown.</li> <li>The space zone for withdrawal of chair is 800mm. Not all chairs achieve this.</li> <li>900mm is recommended for space in front of the easy chairs for leg space and ambulant passing. 860mm is shown where the chairs are opposite the dining tables and chairs.</li> <li>A 100mm gap is recommended between the easy chairs and the wall.</li> </ol>	<ol style="list-style-type: none"> <li>HBN00-03 Clinical and clinical support spaces; pg 79, fig A16</li> <li>HBN00-03 Clinical and clinical support spaces; pg 79, fig A16</li> <li>HBN00-03 Clinical and clinical support spaces; pg 78, fig. A15, pg 50 fig 39.</li> <li>HBN00-03 Clinical and clinical support spaces; pg 50, fig 39 and pg 77 fig A14.</li> <li>HBN00-03 Clinical and clinical support spaces; pg 78 fig A16 and pg 50 fig 39.</li> </ol>	For derogation no. 3, we have based the 800mm for the withdrawal of chair on fig A15 illustrating working at a desk/table. This is because there is no dimension on fig A16 which illustrate the dining table/chair arrangement.
Batch 2	S149	Rest room with beverage : snack preparation bay: 12 staff	<ol style="list-style-type: none"> <li>750mm is recommended for the table size per user. 600mm is shown.</li> <li>The space zone for a place setting on a table should be 400mm x 600mm. 300 x 600 is shown.</li> <li>The space zone for withdrawal of chair is 800mm. Not all chairs achieve this.</li> <li>The space zone for working at the sink (1000mm x 1000mm) and worktop (1000mm depth) overlaps the dining tables.</li> <li>900mm is recommended for space in front of the easy chairs for leg space and ambulant passing. 820mm is shown where the chairs are opposite the dining tables and chairs.</li> <li>A 100mm gap is recommended between the easy chairs and the wall.</li> </ol>	<ol style="list-style-type: none"> <li>HBN00-03 Clinical and clinical support spaces; pg 79, fig A16</li> <li>HBN00-03 Clinical and clinical support spaces; pg 79, fig A16</li> <li>HBN00-03 Clinical and clinical support spaces; pg 78, fig. A15, pg 50 fig 39.</li> <li>HBN00-03 Clinical and clinical support spaces; pg 82, figA19, pg 66 fig A3, pg 50 fig 39.</li> <li>HBN00-03 Clinical and clinical support spaces; pg 50, fig 39 and pg 77 fig A14.</li> <li>HBN00-03 Clinical and clinical support spaces; pg 78 fig A16 and pg 50 fig 39.</li> </ol>	For derogation no. 3, we have based the 800mm for the withdrawal of chair on fig A15 illustrating working at a desk/table. This is because there is no dimension on fig A16 which illustrate the dining table/chair arrangement.

## DEROGATION SCHEDULE

1:50 STANDARD ROOMS

## BATCH 2

F01 - 31/01/11

F02 - 28/02/11

Batch	Room No.	Room Name	Description of derogation	Reference document	BDP Comments
Batch 2	S029	Rest room with beverage: snack preparation bay: 8 staff	<ol style="list-style-type: none"> <li>1. The space zone for working at the sink (1000mm x 1000mm) and worktop (1000mm depth) overlaps adjacent furniture and clinical wash hand basin.</li> <li>2. 600mm is recommended for clearance between easy chairs and low level table for access. This applies to 2no. chairs. None of these chairs achieve this.</li> <li>3. 900mm is recommended for space for ambulant passing and restricted leg space to the easy chairs. This applies to 2no. chairs. None of these chairs achieve this.</li> <li>4. A 100mm gap is recommended between the easy chairs and the wall.</li> </ol>	<ol style="list-style-type: none"> <li>1. HBN00-03 Clinical and clinical support spaces; pg 48 fig 38, pg50 fig 39, pg 82 figA19, pg 66, A3.</li> <li>2. HBN00-03 Clinical and clinical support spaces; pg 77 fig A14, pg 50 fig 39.</li> <li>3. HBN00-03 Clinical and clinical support spaces; pg 77 fig A14, pg 50 fig 39.</li> <li>4. HBN00-03 Clinical and clinical support spaces; pg 78 fig A16 and pg 50 fig 39.</li> </ol>	
Batch 2	S153	Rest room with beverage : snack preparation bay: 10 staff with 10 lockers	<ol style="list-style-type: none"> <li>1. 900mm x 800mm space zone is recommended in front of clinical wash hand basin. The adjacent worktop is within this zone.</li> <li>2. A 100mm gap is recommended between the easy chairs and the wall.</li> <li>3. 1350mm is recommended for space between the easy chairs and upright chairs for leg space and ambulant passing. 1120mm is shown.</li> </ol>	<ol style="list-style-type: none"> <li>1. HBN00-03 Clinical and clinical support spaces; pg 64 fig A1.</li> <li>2. HBN00-03 Clinical and clinical support spaces; pg 78 fig A16 and pg 50 fig 39.</li> <li>3. HBN00-03 Clinical and clinical support spaces; pg 77 fig A14, pg 50 fig 39.</li> </ol>	<p>By reducing the length of the worktop by 100mm, derogation no. 2 could be eliminated.</p> <p>For derogation no. 4, we have based 450mm for the space for leg room on an upright chair on pg 77 fig A14, sitting on a easy chair diagram.</p>
Batch 2	S095	Rest room 5 staff	<ol style="list-style-type: none"> <li>1. A 100mm gap is recommended between the easy chairs and the wall.</li> </ol>	<ol style="list-style-type: none"> <li>1. HBN00-03 Clinical and clinical support spaces; pg 78 fig A16 and pg 50 fig 39.</li> </ol>	

**BATCH 2**

**F01 - 31/01/11**

**F02 - 28/02/11**

Batch	Room No.	Room Name	Description of derogation	Reference document	BDP Comments
Batch-2	S103	Staff changing room : 40 places  ROOM OMITTED FROM 1:50 STANDARD ROOM PROCESS			<p>For changing areas it is recommended that there should be a minimum of one semi-ambulant changing room. This should be included as part of an adjacent room. HBN00-02 Sanitary spaces; pg 68 fig 52, pg67 para 5.63, pg 64 fig 49.</p> <p>Consideration should be given to the provision of independent wheelchair changing rooms in accordance with the requirements of Approved Document M. HBN00-02 Sanitary spaces; pg 67 para 5.63.</p> <p>Building Regulations advise that some wheelchair users will require privacy of a self contained cubicle. In open changing cubicles it is difficult to provide the configuration of handrails, controls and seats for disabled people to use. The overall dimensions and equipment arrangement must comply. This room should be included as part of an adjacent room. Building Regulations, Document M, pg 57 para 5.16, pg 58 para 5.18 item h, pg 59 diagram 22.</p> <p>It is understood that the changing cubicle is to be used for nursing mothers. The Workplace health, safety and welfare document states that where necessary it should include the facility to lie down. Workplace Health, Safety and Welfare Regulations, pg 39, para 237.</p>

Batch	Room No.	Room Name	Description of derogation	Reference document	BDP Comments
Batch 2	S145	Staff changing room: 18 places  <b>ROOM OMITTED FROM 1:50 STANDARD ROOM PROCESS</b>			<p>For changing areas it is recommended that there should be a minimum of one semi-ambulant changing room. This should be included as part of an adjacent room. HBN00-02 Sanitary spaces; pg 68 fig 52, pg67 para 5.63, pg 64 fig 49.</p> <p>Consideration should be given to the provision of independent wheelchair changing rooms in accordance with the requirements of Approved Document M. HBN00-02 Sanitary spaces; pg 67 para 5.63.</p> <p>Building Regulations advise that some wheelchair users will require privacy of a self contained cubicle. In open changing cubicles it is difficult to provide the configuration of handrails, controls and seats for disabled people to use. The overall dimensions and equipment arrangement must comply. This room should be included as part of an adjacent room. Building Regulations, Document M, pg 57 para 5.16, pg 58 para 5.18 item h, pg 59 diagram 22.</p> <p>It is understood that the changing cubicle is to be used for nursing mothers. The Workplace health, safety and welfare document states that where necessary it should include the facility to lie down. Workplace Health, Safety and Welfare Regulations, pg 39, para 237.</p>
Batch 2	S031	Locker Bay : 8 lockers - staff	NO COMMENTS		
Batch 2	S014	WC : independent wheelchair	<ol style="list-style-type: none"> <li>1. The location of the pull cord is recommended to be in the same line as the end of the WC.</li> <li>2. It is recommended that the paper towel dispenser above the wash hand basin is located on the right (the side nearest the wc) and the soap dispenser is located on the left. The soap dispenser on the right and paper towel on the left is shown.</li> <li>3. The height recommended for the call reset CAL012 is 800-1000mm to the bottom. The height shown is 1050mm.</li> </ol>	<ol style="list-style-type: none"> <li>1. HBN00-02 Sanitary spaces; pg 16, fig 9.</li> <li>2. HBN00-02 Sanitary spaces; pg 16, fig 9.</li> <li>3. HBN00-02 Sanitary spaces; pg 16, fig 9.</li> </ol>	

Batch	Room No.	Room Name	Description of derogation	Reference document	BDP Comments
Batch 2	S026	WC : wheelchair Doc M	HBN derogations do not apply to this room. This room is to be compliant with Building Regulations.		In order to comply with Building Regulations, the following amendments need to be made: <ul style="list-style-type: none"> <li>- The current wash hand basin needs to be replaced with a smaller hand rinse basin (300mm x 370mm).</li> <li>- The height of the reset button needs to be lowered to 800 – 1000mm AFFL.</li> <li>- The towel dispenser and soap dispenser need to swap positions.</li> <li>- The position of the pull cord needs to be nearer the WC.</li> </ul>
Batch 2	S015	WC : semi-ambulant	1. The location of the pull cord is recommended to be nearer the WC.	1. HBN00-02 Sanitary spaces; pg 12, fig 5.	
Batch 2	S155	WC: ambulant - staff	1. It is recommended that the shelf be located on the same wall as the wash hand basin. The shelf is shown on the opposite wall.	1. HBN00-02 Sanitary spaces; pg 10, fig 2.	
Batch 2	S132	Adult Changing (Panic)  ROOM OMITTED FROM 1:50 STANDARD ROOM PROCESS	<ol style="list-style-type: none"> <li>1. A 900mm unobstructed zone around the changing table is recommended. The zone is obstructed by the clinical wash hand basin and HOL008.</li> <li>2. A shelf is recommended to be located adjacent to the changing table. The shelf is not shown.</li> <li>3. It is recommended that a personal wash hand basin is used. A clinical hand wash basin is shown.</li> <li>4. It is recommended that an independent wheelchair toilet with associated wash-hand basin should be included. These are not shown.</li> <li>5. This room does not allow space for a wheelchair.</li> </ol>	<ol style="list-style-type: none"> <li>1. HBN00-02 Sanitary spaces; pg 61, fig 45.</li> <li>2. HBN00-02 Sanitary spaces; pg 61, fig 45.</li> <li>3. HBN00-02 Sanitary spaces; pg 61, fig 45 and pg 60 para 5.12.</li> <li>4. HBN00-02 Sanitary spaces; pg 61, fig 45 and pg 60 para 5.14.</li> <li>5. HBN00-02 Sanitary spaces; pg 61, fig 45 and pg 60 para 5.17.</li> </ol>	
Batch 2	S131	Staff sanitary facility : 1 WC, 2 handwash, 1 shower	NO COMMENTS		
Batch 2	S028	Shower room : ambulant staff	NO COMMENTS		
Batch 2	S134	Shower: WC and wash; ambulant (non-patient); ensuite	<ol style="list-style-type: none"> <li>1. 1100mm height for the soap dish is recommended. 1305mm is shown.</li> <li>2. It is recommended that an unobstructed space zone in front of the WC should be 600mm x 800mm. The wash hand basin and sack holder currently obstruct this zone.</li> <li>3. It is recommended that an unobstructed space zone for dressing and undressing should be 1500mm x 1200mm. This zone is obstructed by the wash hand basin and the WC.</li> </ol>	<ol style="list-style-type: none"> <li>1. HBN00-02 Sanitary spaces; pg 26 fig 16.</li> <li>2. HBN00-02 Sanitary spaces; pg 10 fig 3.</li> <li>3. HBN00-02 Sanitary spaces; pg 26 fig 16 and pg 27 fig 17.</li> </ol>	There isn't sufficient room area to comply with the HBN clear space zones. The area of the room would have to be increased in order to comply with HBN.

## DEROGATION SCHEDULE

1:50 STANDARD ROOMS

## BATCH 2

F01 - 31/01/11

F02 - 28/02/11

Batch	RoomNo	Room Name	Description of derogation	Reference document	BDP Comments
Batch 2	S045	Nappy changing room	<ol style="list-style-type: none"> <li>1. It is recommended that an unobstructed zone of 800mm width is located in front of the nappy changing worktop. Currently this zone is obstructed by the WC.</li> <li>2. It is recommended that nappy changing facilities are provided separately from WC provisions. A WC is shown in this room.</li> <li>3. A shelf is recommended located adjacent to the wash hand basin. No shelf is shown.</li> </ol>	<ol style="list-style-type: none"> <li>1. HBN00-02 Sanitary spaces; pg 59 fig 44.</li> <li>2. HBN00-02 Sanitary spaces; pg 26 fig 16 and para 5.9.</li> <li>3. HBN00-02 Sanitary spaces; pg 59 fig 44.</li> </ol>	
Batch 2	S087	Beverage : snack preparation bay	<ol style="list-style-type: none"> <li>1. 800mm is recommended as worktop or drainer space to each side of the sink. 700mm is shown on one side.</li> <li>2. A hand rinse basin is recommended. A clinical wash hand basin is shown.</li> </ol>	<ol style="list-style-type: none"> <li>1. HBN00-03 Clinical and clinical support spaces; pg 66, fig A3.</li> <li>2. HBN00-03 Clinical and clinical support spaces; pg 46, fig 37.</li> </ol>	
Batch 2	S086	Beverage : snack preparation bay	<ol style="list-style-type: none"> <li>1. 800mm is recommended as worktop or drainer space to each side of the sink. 700mm is shown on one side.</li> <li>2. A hand rinse basin is recommended. A clinical wash hand basin is shown.</li> </ol>	<ol style="list-style-type: none"> <li>1. HBN00-03 Clinical and clinical support spaces; pg 66, fig A3.</li> <li>2. HBN00-03 Clinical and clinical support spaces; pg 46, fig 37.</li> </ol>	
Batch 2	S136	Pantry Cook Chill Hot Trolleys up to 80 persons	NO COMMENTS - KITCHEN SPECIALIST FIT OUT		
Batch 2	S044	Pantry Cook Chill Hot Trolleys up to 32 persons	NO COMMENTS - KITCHEN SPECIALIST FIT OUT		
Batch 2	S135	Pantry Cook Chill Hot Trolleys up to 24 persons	NO COMMENTS - KITCHEN SPECIALIST FIT OUT		
Batch 2	S107	Infant feeding room	NO COMMENTS		
Batch 2	S140	Store : clinical equipment	NO COMMENTS		
Batch 2	S141	Store : bulk supplies ; medical and surgical	<ol style="list-style-type: none"> <li>1. For tall modular storage cabinets (MSC041) it is recommended that 1800mm is allowed for accessing storage and circulation. 1230mm is shown.</li> </ol>	<ol style="list-style-type: none"> <li>1. HBN00-03 Clinical and clinical support spaces; pg 83, fig A20.</li> </ol>	
Batch 2	S061	Equipment Store ( Medical)	NO COMMENTS		

## DEROGATION SCHEDULE

1:50 STANDARD ROOMS

## BATCH 2

F01 - 31/01/11

F02 - 28/02/11

Batch	RoomNo	Room Name	Description of derogation	Reference document	BDP Comments
Batch 2	S141	Store : bulk supplies ; medical and surgical	1. For tall modular storage cabinets (MSC041) it is recommended that 1800mm is allowed for accessing storage and circulation. 1200mm is shown.	1. HBN00-03 Clinical and clinical support spaces; pg 83, fig A20.	
Batch 2	S063	Equipment store	NO COMMENTS		
Batch 2	S065	Equipment store	NO COMMENTS		
Batch 2	S064	Equipment store (medical)	NO COMMENTS		
Batch 2	S101	Store : general supplies	NO COMMENTS		
Batch 2	S100	Store : general supplies	NO COMMENTS		
Batch 2	S139	Store : linen	1. 1100mm is recommended for access to shelves while bending. We show 1045mm.	1. HBN00-03 Clinical and clinical support spaces; pg 84, fig A21.	
Batch 2	S025	Store : consumables	1. 1100 is recommended to access to shelves while bending. We show 1020mm.	1. HBN00-03 Clinical and clinical support spaces; pg 84, fig A21.	The room could be re-proportioned to eliminate the derogation.
Batch 2	S024	Store – ready to use – medical gas cylinders	NO COMMENTS		
Batch 2	S137	Hold - Disposal	1. 200mm clear zone is recommended around each bin. This is not shown. 2. 1200mm clear zone is recommended between each bin. 1000mm is shown. 3. Door should open out. An opening in door is shown.	1. HBN00-03 Clinical and clinical support spaces; pg 43, fig 34. 2. HBN00-03 Clinical and clinical support spaces; pg 43, fig 34. 3. HBN00-03 Clinical and clinical support spaces; pg 43, fig 34.	
Batch 2	S138	Hold - Disposal	1. 200mm clear zone is recommended around each bin. This is not shown. 2. 1200mm clear zone is recommended between each bin. 1000mm is shown. 3. Door should open out. An opening in door is shown.	1. HBN00-03 Clinical and clinical support spaces; pg 43, fig 34. 2. HBN00-03 Clinical and clinical support spaces; pg 43, fig 34. 3. HBN00-03 Clinical and clinical support spaces; pg 43, fig 34.	

## DEROGATION SCHEDULE

1:50 STANDARD ROOMS

## BATCH 2

F01 - 31/01/11

F02 - 28/02/11

Batch	Room No	Room Name	Description of derogation	Reference document	BDP Comments
Batch 2	S069	Hold - Disposal	<ol style="list-style-type: none"> <li>200mm clear zone is recommended around each bin. This is not shown.</li> <li>1200mm clear zone is recommended between each bin. This zone is obstructed.</li> <li>Door should open out. An opening in door is shown.</li> </ol>	<ol style="list-style-type: none"> <li>HBN00-03 Clinical and clinical support spaces; pg 43, fig 34.</li> <li>HBN00-03 Clinical and clinical support spaces; pg 43, fig 34.</li> <li>HBN00-03 Clinical and clinical support spaces; pg 43, fig 34.</li> </ol>	
Batch 2	S068	Hold - Disposal	<ol style="list-style-type: none"> <li>200mm clear zone is recommended around each bin. This is not shown.</li> <li>1200mm clear zone is recommended between each bin. This zone is obstructed.</li> <li>Door should open out. An opening in door is shown.</li> </ol>	<ol style="list-style-type: none"> <li>HBN00-03 Clinical and clinical support spaces; pg 43, fig 34.</li> <li>HBN00-03 Clinical and clinical support spaces; pg 43, fig 34.</li> <li>HBN00-03 Clinical and clinical support spaces; pg 43, fig 34.</li> </ol>	
Batch 2	S054	Linen bay : exchange trolley	<ol style="list-style-type: none"> <li>1100mm clear zone in front of the shelves is recommended for bending. 400mm is shown in the corner areas.</li> </ol>	<ol style="list-style-type: none"> <li>HBN00-03 Clinical and clinical support spaces; pg 84, fig A21.</li> </ol>	
Batch 2	S156	Linen bay : associated with patient changing	NO COMMENTS		
Batch 2	S013	Parking bay	NO COMMENTS		
Batch 2	S020	Parking bay: trolleys and wheelchair	NO COMMENTS		
Batch 2	S078	Cleaners room	<ol style="list-style-type: none"> <li>It is recommended that the door opens out. An inward opening door is shown.</li> </ol>	<ol style="list-style-type: none"> <li>HBN00-03 Clinical and clinical support spaces; pg 42, fig 33.</li> </ol>	
Batch 2	S023	Switchgear cupboard	NO COMMENTS		
Batch 2	S001	Day/Overnight Room Twin Bedroom	<ol style="list-style-type: none"> <li>A clear zone of 700mm around the bed is recommended for ambulant access to the bed. The chair obstructs this zone at the end of one bed.</li> <li>There is no space for a wheelchair turning circle at the side of the bed.</li> </ol>	<ol style="list-style-type: none"> <li>HBN00-03 Clinical and clinical support spaces; pg 76, fig A13 and pg 45 fig 36.</li> <li>HBN00-03 Clinical and clinical support spaces; pg 76, fig A13 and pg 45 fig 36.</li> </ol>	
Batch 2	S133	Day/overnight room : single bedroom relatives	<ol style="list-style-type: none"> <li>There is no space for a wheelchair turning circle at the side of the bed.</li> </ol>	<ol style="list-style-type: none"> <li>HBN00-03 Clinical and clinical support spaces; pg 76, fig A13 and pg 45 fig 36.</li> </ol>	